



**ADDENDUM #1**

December 2, 2024

JOB # BC2024-01

**RE-BID: 2024 BUILDING RENOVATIONS, CITY OF ALEXANDRIA SWAT BUILDING**

CITY OF ALEXANDRIA, LOUISIANA – OWNER

**BID DATE: TUESDAY, DECEMBER 10<sup>th</sup>, 2024 @10:00 AM**

\*\*\*\*\*

Each bidder shall note on his Bid Form receipt of the Addendum and number; that his Bid is for the conditions set forth in this Addendum plus the complete Contract Documents.

SOLE RESPONSIBILITY FOR PROPER DELIVERY OF BID IN COMPLIANCE WITH THE OFFICIAL PROJECT ADVERTISEMENT IS THAT OF THE GENERAL CONTRACTOR'S.

**ARCHITECTURAL :**

08361 Sectional Overhead Doors – Finish – Shall be from manufactures standard Colors

08710 – Door Hardware – Best Cores shall be supplied by the hardware supplier. Keying of the cores shall be per the City of Alexandria's Coring system.

10522 : Fire Extinguishers. – Provide four (4) Type ABC 5 lb. extinguishers with surface mounted cabinets. Mounting locations as directed by architect.

Building Insulation : Any missing insulation in the walls, or ceiling cavities shall be supplied by the city and shall be installed by the contractor. ( unfaced fiberglass 3 ½" for walls and 6 – 8 inch for ceiling / roof cavities.)

**OTHER ACCEPTABLE MANUFACTURERS:**

No Exceptions are taken to the following manufacturers and/or products for bidding purposes in addition to those specified. Substituting products other than those specified is based upon the best information now available. Should any modification be required to accommodate the substitute product, it is the responsibility of this supplier and/or subcontractor to include the cost of this modification in his quotation. It should be understood that any deviation from the products specified with respect to quality, details, and performance in the opinion of the Architect is grounds for disapproval of this product subsequent to a contract award. Any manufacturer or product that is not listed here in the Specifications shall be deemed NOT ACCEPTABLE for this project. Verification of this is the responsibility of the General Contractor. The Architect, after the Contract Award, will strictly enforce this policy.

**Electrical Prior Approvals: Lighting**

**Item Manufacturer**

B2- DAY BRITE B2E- DAY BRITE B3- DAY BRITE B4- DAY BRITE B4E- DAY BRITE C4- DAY BRITE CF- TRULY GREEN SOLUTIONS E- CHLORIDE E1- LIFE SAFETY LIGHTING F2- STONCO HB- DAY BRITE SL-LIGHTOLIER T- CONTECH LIGHTING TL- CONTECH LIGHTING; Color temp to be 3500K as indicated on plans X1- CHLORIDE Power Packs WATTSTOPPER Sensors/Switches WATTSTOPPER

**END OF ADDENDUM #1 (ONE)**